



PDC Laboratories, Inc.

PROFESSIONAL • DEPENDABLE • COMMITTED

December 13, 2017

Terry Glazik
St. Malachy School
340 E. Belle
Rantoul, IL 61866

Dear Terry Glazik:

Please find enclosed the analytical results for the sample(s) the laboratory received on **11/29/17 9:20 am** and logged in under work order **7114416**. All testing is performed according to our current TNI certifications unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of PDC Laboratories, Inc.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

PDC Laboratories, Inc. appreciates the opportunity to provide you with analytical expertise. We are always trying to improve our customer service and we welcome you to contact the Vice President, John LaPayne with any feedback you have about your experience with our laboratory.

Sincerely,

Senior Project Manager
(309) 692-9688 x1719
kstepping@pdclab.com





ANALYTICAL RESULTS

Sample: 7114416-01
Name: KITCHEN SINK WEST WALL #1 FAUCET 1ST DRAW
Alias: ST. MALACHY

Sampled: 11/28/17 06:16
Received: 11/29/17 09:20
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	1.13	ug/L		12/12/17 06:43	12/12/17 14:38	KMC	EPA 200.8

Sample: 7114416-02
Name: KITCHEN SINK WEST WALL #1 FAUCET 2ND DRAW
Alias: ST. MALACHY

Sampled: 11/28/17 06:17
Received: 11/29/17 09:20
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		12/12/17 06:43	12/12/17 14:39	KMC	EPA 200.8

Sample: 7114416-03
Name: KITCHEN SINK WEST WALL #2 FAUCET 1ST DRAW
Alias: ST. MALACHY

Sampled: 11/28/17 06:20
Received: 11/29/17 09:20
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		12/12/17 06:43	12/12/17 14:40	KMC	EPA 200.8

Sample: 7114416-04
Name: KITCHEN SINK WEST WALL #2 FAUCET 2ND DRAW
Alias: ST. MALACHY

Sampled: 11/28/17 06:21
Received: 11/29/17 09:20
Matrix: Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
Total Metals - PIA							
Lead	< 1.00	ug/L		12/12/17 06:43	12/12/17 14:41	KMC	EPA 200.8



PDC Laboratories, Inc.
2231 West Altorfer Drive
Peoria, IL 61615
(800) 752-6651

NOTES

Specific method revisions used for analysis are available upon request.

Certifications

CHI - McHenry, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100279
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL

TNI Accreditation for Drinking Water, Wastewater, Hazardous and Solid Wastes Fields of Testing through IL EPA Lab No. 100230
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 17553
Wastewater Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)
Hazardous/Solid Waste Certifications: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO

USEPA DMR-QA Program

STL - St. Louis, MO

TNI Accreditation for Wastewater, Hazardous and Solid Wastes Fields of Testing through KS Lab No. E-10389
Illinois Department of Public Health Bacteriological Analysis in Drinking Water Approved Laboratory Registry No. 171050
Drinking Water Certifications: Missouri (1050)
Missouri Department of Natural Resources

* Not a TNI accredited analyte

Certified by: Kurt Stepping, Senior Project Manager



PDC LABORATORIES, INC.
 2231 WEST ALTORFER DRIVE
 PEORIA, IL 61615
 Phone: (800) 752-8681 Fax: (309) 692-9688

CHAIN OF CUSTODY RECORD
 ILLINOIS SCHOOLS LEAD TESTING

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT ST. MARY'S SCHOOL 340 East 80th St Peoria, IL 61666		P.O. NUMBER SCHOOL NAME ST. MARY'S		PHONE NUMBER 217 932 2044		EMAIL ST. MARY'S		3 ANALYSIS REQUESTED	
2 SAMPLE INFORMATION Kitchen Sink Westfall #1 Street Kitchen Sink Westfall #2 Street Ke Test		DATE RECEIVED 11/24/12 TIME RECEIVED 10:30 AM 6:20 AM		MATRIX TYPES: WW-WATER/WATER DW-DRAINING WATER OW-OPENING WATER HW-SEWAGE LW-LEAKAGE LW-SOLID LW-LEACHATE OTHER:		MEANS SHIPPED DATE SHIPPED		LEAD 200.8	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH RESULTS SUBJECT TO POC LABS APPROVAL AND SCHEDULING) RUSH RESULTS VIA (PLEASE CIRCLE) FAX PHONE PHONE # IF DIFFERENT FROM ABOVE: 251 295 2546		RUSH DATE RESULTS NEEDED		6 The sample temperature will be measured upon receipt at the lab. By initiating this assay you request that the lab notify you, before proceeding with analysis, if the sample temperature is outside of the range of 0-14.0°C. By not including this area you allow the lab to proceed with analytical testing regardless of the sample temperature.		(FOR LAB USE ONLY) LOGIN # 7114414-4 LAB PROJ. # TEMPLATE: PROJ. MOR: KURT STEPPING		DATE/TIME LAST USED	
7 RELINQUISHED BY: (SIGNATURE) DATE TIME RECEIVED BY: (SIGNATURE) DATE TIME		RECEIVED BY: (SIGNATURE) DATE TIME		RECEIVED BY: (SIGNATURE) DATE TIME		SAMPLE TEMPERATURE UPON RECEIPT CHILL PROCESS STARTED PRIOR TO RECEIPT SAUER (S) RECEIVED ON ICE PROPER BOTTLES RECEIVED IN GOOD CONDITION BOTTLES FILLED WITH APPROPRIATE VOLUME SAMPLES RECEIVED WITHIN HOLD TIMES (EXCLUDES TYPICAL FIELD PARAMETERS) DATE AND TIME TAKEN FROM SAMPLE BOTTLE		COMMENTS: (FOR LAB USE ONLY) 14 °C	

ISBE ID	BLDG ID	BLDG DESCR	SAMPLE DATE	SAMPLE TIME	COLLECTED BY	SAMPLE ID #	SAMPLE LOCATION DESCRIPTION	FIXTURE TYPE
			11/28/2017	06:16	Terry Glazik	7114416-01	KITCHEN SINK WEST WALL #1 FAUCET 1ST DRAW	
			11/28/2017	06:17	Terry Glazik	7114416-02	KITCHEN SINK WEST WALL #1 FAUCET 2ND DRAW	
			11/28/2017	06:20	Terry Glazik	7114416-03	KITCHEN SINK WEST WALL #2 FAUCET 1ST DRAW	
			11/28/2017	06:21	Terry Glazik	7114416-04	KITCHEN SINK WEST WALL #2 FAUCET 2ND DRAW	

DATE OF LAST USE	TIME OF LAST USE	SAMPLE TYPE	SAMPLE VOLUME(ml)	LabName	MethodName	CONCENTRATION(ug/l)	ReportingLevel(ug/l)
		250		PDC Laboratories, Inc.	EPA 200.8	1.13	1.00
		250		PDC Laboratories, Inc.	EPA 200.8	ND	1.00
		250		PDC Laboratories, Inc.	EPA 200.8	ND	1.00
		250		PDC Laboratories, Inc.	EPA 200.8	ND	1.00